



**COLLEGE OF AGRICULTURE - LALSOT**  
(Sri Karan Narendra Agriculture University-Jobner)  
कृषि महाविद्यालय लालसोट, जिला दौसा (राज.) - 303511



DEAN

No. F./ACL/Store/2023/2169

Mob. No. - 9928402564

Email: dean.coalalsot@sknau.ac.in

Date:30.01.2023

**LIMITED TENDER**

Sealed tenders are invited from firms/ Battery suppliers/contractors for providing online UPS/batteries/wires and stand at COA, Lalsot. The tenders will be accepted upto 06.02.2023 (11.30AM) and will be opened on the same day at 12.30 PM in office of Dean, COA, Lalsot by the committee. The committee has all rights to accept or reject any tender without assigning the reasons thereof. The earnest money is Rs 3400.00 which is to be deposited in office of Dean, COA, Lalsot. Agreement of UPS/batteries and installation work will be done on Non-judicial stamp paper of Rs 100.00 whose expenditure will be borne by the firm.

**Terms and conditions:**

1. The firm should submit their address, Aadhar, GST registration with rates (FOR COA, Lalsot)
2. Firm may visit the campus from 10.00AM-5.00PM for estimation of exact work which is to be done at COA,Lalsot.
3. Firm will submit rates in the following table(specification mentioned) for quoting the rates.

S.No.	Specification of required items	Qty.	Basic rate Rs	GST		Total Rs
				GST%	Amount Rs	
1	<b>1 KVA &amp; 3 KVA Online UPS (External Battery Type)</b> <b>UPS TYPE</b> 1. Minimum Backup Time 2 Hours or More. 2. Unity Power Factor Output with 8 or more Battery Option. 3. High Efficiency upto 91% & True Double Conversion. 4. DSP Technology Guarantees High Performance. 5. Wide Input Voltage Range (110-300 VAC) & Light Weight UPS. 6. Active Input Power Factor Correction 0.99 7. 50Hz/60Hz Frequency Converter Mode & Emergency Power Off Function (EPO). 8. ECO Mode Efficiency upto 98% for Energy Saving. 9. Adjustable Battery Numbers 10. Generator Compatible 11. SNMP/USB/RS-232 Communications & Maintenance Bypass. 12. Static Bypass Available & Optional N+X Para 13. Inbuilt OVCD 14. Reputed Company 15. Minimum 1 Year Warranty	01(1KVA)  01(3KVA)				
2	<b>Battery: Battery Type</b> 1. Lead Acid Battery 2. Minimum 65 AH or Above for 2 Hours Backup 3. 12 V Supply 4. Nominal Input Voltage 135-300 AC/50Hz+5% 5. Output Voltage 230 V VA 6. SMF Battery 7. Reputed Brands (Luminous/Exide/Amaron/Microtek) 8. Compatible with Online UPS 9. Minimum 2 Year Warranty	11				
3	<b>WIRE: Wire Type</b> 1. Copper Wire 2. 1.5 MM or Above 3. Reputed Brands (Havells, Finolex, Polycab, RR)	03				
4	<b>Stand for All Online UPS and Batteries</b>	02				
5	<b>Installation of all Online UPS with All Batteries at COA,Lalsot</b>	-				
6	<b>All Smart Classrooms connections with Online UPS</b>	-				

4. Responsibility of GST/tax/labours/transport/others charges will be of firm.
5. Payment will be made after satisfactory completion of work in the account of firm.
6. Firm will be responsible for proper working of UPS/batteries during warranty period.
7. Proper installation and working of UPS and batteries will be responsibility of firm.



DEAN

Copy to following for information:

1. The Convener/DDO, all member of tender committee
2. Incharge, Store,COA,Lalsot
3. I/C, CIMCA, SKNAU, Jobner with request to upload on University website and Govt portal
4. Notice Board, COA,Lalsot, Nagarpalika,Lalsot and Deedwana Panchayat Deedwana



I/C STORE